

SAFETY WALKAROUND CHECKLIST PORTABLE LADDERS

2001

| Date Prepared: | By: | |
|---|--|-------|
| Project Name/No: | | |
| Check the box if the statement is true. | | |
| Citations in brackets are from Title 8 of th | e California Administrative Code. | |
| | | NOTES |
| INSPECTIONS | | NOTES |
| ☐ The company has a written Injury and (IIPP) that meets all Cal/OSHA require identification of ladder hazards on the accident investigation, and correction of the contraction of the company has a written Injury and (IIPP) that meets all Cal/OSHA require identification of the company has a written Injury and (IIPP) that meets all Cal/OSHA require identification of the company has a written Injury and (IIPP) that meets all Cal/OSHA require identification of the company has a written Injury and (IIPP) that meets all Cal/OSHA require identification of the contraction of the cont | ements. It includes site, regular inspections, | |
| ☐ All defective ladders are tagged and in | nmediately removed. [1675(b)] | |
| ☐ Ladders have no broken or defective ru are firmly attached to side rails. [1675(b | | |
| ☐ Ladders have no nails, screws, or splin | ters sticking out. [3278(c)] | |
| \square Rungs have no oil or grease on them. | 3278(e)(6) and 3279(d)(4)] | |
| ☐ Non-slip safety feet or bases on ladders | s are in good condition. | |
| ☐ Non-slip safety material on ladder run | gs is in good condition. | |
| ☐ Interiors of open end hollow rungs of n corrosion. [1675(b)] | netal ladders are free from | |
| USE OF LADDERS | | |
| ☐ Unless there are stairways or ramps, l points in frequently traveled passagew there is a break in elevation of 18 inch | ays, entries, or exits where | |
| ☐ Ladders are used for access to working ground level only on a short-duration j permanent means of access. [1629(a)(1)] | · | |
| ☐ Ladders are used for access to roof and frame buildings. [1629(b)(1)(B)] | l attic work areas in wood | |

NOTES

| | Ladders are used for access to points above the highest floor that has been planked or decked in steel frame buildings. (Stairways should extend to the highest planked floor.) [1629(b)(2)] |
|-------|---|
| | Ladders are used for access to scaffolds. [1637(n)] |
| | Ladders are used for access to levels in a vertical shoring system above the lowest floor in concrete buildings. (There must be at least two ladders in different locations for each floor, and ladders may not be used for more than three floors.) [1629(b)(3)] |
| LADDI | ER SPECIFICATIONS |
| | Rungs are uniformly spaced no more than 12 inches apart vertically. [1676(c)] |
| | Stepladders do not exceed 20 feet. [3278(d)(1)(A)] |
| | Extension ladders do not exceed 44 feet when extended. [1678(a)] |
| | Extension ladders are not used fully extended. There is an overlap between sections, not less than 10% of the working length of the ladder. [1678(b)] |
| | Portable metal ladders are marked with a sign cautioning against use near electrical equipment. [3279(d)(11)] |
| | Portable ladders are labeled as being in accordance with American National Standards Institute (ANSI) standards A 14.1 1982, <i>Portable Wood Ladders</i> , or A 14.2 1982, <i>Portable Metal Ladders</i> . [1675(c) and (d)] |
| USE O | F CORRECT LADDER |
| | No portable metal ladder is used for electrical work, near live electrical parts, or within six feet of high voltage lines. (Increase the distance for very high voltage.) [1675(l), 2946, and 3279(d)(11)] |
| | Double cleat ladders are used if there is 2-way traffic or traffic by 25 or more workers. (Double cleat ladders should not exceed 30 feet in length.) $[1629(c)(2)]$ |
| | Single-rail ladders are prohibited on the site. [3276(a)(4)] |
| | Short ladders are not spliced together to make a longer one. $[3278(e)(13)]$ |
| PLACI | EMENT |
| | Areas where ladders are placed are clear at the top and bottom, and are not greasy or muddy. [1675(e)] |

NOTES

| | Ladders are placed on firm dry ground, so they won't slip or sink, and are not placed on boxes or other unstable bases. [1675(e)] |
|------|--|
| | Ladders are not placed where they can be bumped (for example, a doorway, passageway, or driveway). Ladders which may be struck or displaced are barricaded or guarded. [1675(h)] |
| | Portable ladders are tied, blocked, or otherwise secured. [1675(j)] |
| | Portable ladders are placed 1 foot out from the wall for every 4 feet of ladder length (75° pitch). $[1675(g)]$ |
| WORK | (PRACTICES |
| | No one stands or works on the top three rungs of a ladder that has no handholds, unless the structure provides a firm handhold or the worker is tied off. $[1675(k)]$ |
| | Workers face a ladder while climbing and descending. [3276(a)(2)] |
| | Stepladders are always opened fully. |
| | Workers do not stand or work on the top (cap) of a stepladder, or the step below the cap. $\[1675(n)\]$ |
| | Planks are not placed on the top (cap) of a stepladder. [1675(f)] |
| | Workers use a ladder one at a time unless the ladder is specially designed for more people. [3278(e)(8)] |
| | Ladders are not used as guys, braces, skids, gin poles, or for other than their intended purpose. [3278(e)(15) and 3279(d)(10)] |
| | Workers adjust extension ladders only when standing at the base, not while on or above the ladder. |
| | Ladders are placed so that side rails extend at least 3 feet above the landing or level they serve. $[1629(c)(3)]$ |
| | Workers do not carry tools, equipment, or materials (except on a tool belt) while on a ladder. [3276(a)(1)] |